

NOTES

- A.** ALL STORM SEWER CONSTRUCTION SHALL ADHERE TO ODOT SPECIFICATIONS LATEST REVISION OR WITH THE VILLAGE STORM SEWER SPECIFICATIONS, WHICHEVER IS APPLICABLE AND MORE RESTRICTIVE.
- B.** HUCKY PUCK IS REQUIRED ON ALL NON O-RING STORM SEWER AND MANHOLES, UNLESS OTHERWISE APPROVED.
- C.** WHEN A CASTING IS ABANDONED IT REMAINS VILLAGE PROPERTY.
- D.** ANY DETAILS OR NOTES NOT DIRECTLY ADDRESSED IN THESE ENGINEERING STANDARDS WILL BE REFERRED TO ODOT STANDARD DRAWINGS AND SPECIFICATIONS.
- E.** ALL STORM SEWER SHALL BE INSTALLED USING A LASER FOR GRADE AND ALIGNMENT.

UTILITY STAKING

- A.** OFFSET AND GRADE AT EACH MANHOLE, CATCH BASIN, AND OTHER STRUCTURES, OFFSET AND GRADE 50' AND 100' OUT FROM EACH MANHOLE UNLESS OTHERWISE APPROVED.

PIPE

- A.** ALL STORM SEWER PIPE SHALL HAVE A MINIMUM DIAMETER OF 12", UNLESS OTHERWISE APPROVED.
- B.** TYPES OF PIPE PERMITTED

UP TO 30" DIAMETER

REINFORCED CONCRETE PIPE	706.02
REINFORCED CONCRETE ELLIPTICAL PIPE	706.04
CORRUGATED POLYETHYLENE SMOOTH-LINED PIPE	707.33
POLYVINYL CHLORIDE PLASTIC PIPE (NON-PERFORATED)	707.41
POLYVINYL CHLORIDE CORRUGATED SMOOTH-INTERIOR PIPE	707.42
POLYVINYL CHLORIDE PROFILE WALL PIPE	707.43
POLYVINYL CHLORIDE SOLID WALL PIPE	707.45

ODOT MATERIALS NUMBER

OVER TO 30" DIAMETER

REINFORCED CONCRETE PIPE	706.02
REINFORCED CONCRETE ELLIPTICAL PIPE	706.04

ODOT MATERIALS NUMBER

EXISTING TILE HOOKUPS

- A.** THE DRAINAGE TILE CURRENTLY CONNECTED TO THE EXISTING STORM SEWER SHALL BE CONNECTED TO THE PROPOSED STORM SEWER. ANY DRAINAGE TILE DAMAGED BY THE CONTRACTOR SHALL BE REPLACED BY THE CONTRACTOR TO A CONDITION EQUAL TO OR BETTER THAN ITS ORIGINAL CONDITION. ALL THE REMOVED, REPLACED, AND/OR CONNECTED TO THE STORM SEWER SHALL BE NOTED ON THE AS-BUILT DRAWINGS AND SHALL BE INSPECTED BY THE INSPECTOR BEFORE THEY ARE COVERED.
- B.** ALL FIELD OR STORM DRAINS WHICH ARE ENCOUNTERED DURING CONSTRUCTION SHALL BE PROVIDED WITH UNOBSTRUCTED OUTLETS OR PLUGGED AS APPROVED AND DIRECTED BY THE VILLAGE.

NEW CONSTRUCTION

- A.** ALL NEW CONSTRUCTION IS REQUIRED TO CONNECT TO THE STORM SEWER. ALL STORM WATER GENERATED WITHIN A LOT MUST BE DISPOSED OF WITHIN SAID LOT SO THIS WATER DOES NOT BECOME A NUISANCE FOR ADJACENT PROPERTIES.

VILLAGE OF
 CHOICE
 ADA
 ONE ENGINEERING

MISCELLANEOUS STORM NOTES

REVISIONS: AUG. 1999	DATE APPROVED: MAY 1997
	PAGE No. 600-10