



**NOTES.**

- A. DIMENSIONS SHOWN ARE INSIDE MEASUREMENTS OF PIT.
- B. ALL PIPE SHALL BE C153 DUCTILE WITH FLANGED ENDS.  
(COPPER & BRASS MAY BE ACCEPTABLE. SUBMIT FOR APPROVAL)
- C. ALL VALVES SHALL BE FLANGED END, HANDWHEEL OPERATED, AND OS&Y GATE VALVES, RESILIENT WEDGE.
- D. PIT SHALL HAVE AN INSIDE HEIGHT OF 6' MINIMUM, FROM TOP OF GRAVEL.
- E. WALLS TO BE FORMED CONCRETE.
- F. PIT TO BE DESIGNED BY REGISTERED ENGINEER OR ARCHITECT AND APPROVED BY THE VILLAGE.
- G. 12" MINIMUM 3/4" WASHED GRAVEL IN BOTTOM OF PIT OR CONCRETE SLAB WITH SWAMP HOLE.
- H. PIPING AND METER SHALL BE SUPPORTED
- I. ALTERNATE DESIGNS MAY BE SUBMITTED FOR APPROVAL. SUBMIT COMBINATION PIT INSTALLATIONS FOR APPROVAL CLEARANCES.

VILLAGE OF  
ADA



**3" AND 4" METER PIT INSTALLATIONS  
(FOR OFF ROAD USE ONLY)**

REVISIONS:

DATE  
APPROVED:  
AUG. 1999

PAGE No.  
800-11